

WAC 246-215-05245 Backflow prevention device, when required (2009 FDA Food Code 5-203.14). A PLUMBING SYSTEM must be installed to preclude backflow of a solid, liquid, or gas contaminant into the water supply system at each point of use at the FOOD ESTABLISHMENT, including on a hose bibb if a hose is attached or on a hose bibb if a hose is not attached and backflow prevention is required by LAW, by:

- (1) Providing an air gap as specified under WAC 246-215-05215; or
- (2) Installing an APPROVED backflow prevention device as specified under WAC 246-215-05220.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05245, filed 1/17/13, effective 5/1/13.]